



**Environmental and Laboratory Services**

Dover Location:  
90 1/2 West Blackwell St., Dover, NJ 07801  
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:  
8A Railroad Ave, Marlboro, NJ 07746  
Phone: (732) 308-3500, Fax (732) 308-3503

Date: January 20, 2022  
Client: High Point Regional HS  
Address: 299 Pidgeon Hill Rd  
Wantage, NJ 07461

PWSID#:  
Project Location:

## Analytical Results

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-001						
Sample Location:	Field Blank	Customer Sample Number:							
Sampled By:	R. Sypniewski								
Sample Date/Time:	12/29/2021 7:09								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	18:00	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-002						
Sample Location:	Hallway by Room 113 01	Customer Sample Number:							
Sampled By:	R. Sypniewski								
Sample Date/Time:	12/29/2021 7:10								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	20:40	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-003
Sample Location:	Hallway by Room 113 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:11		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.42	µg/L	15	1/10/2022	13:04	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-004
Sample Location:	Teachers Rm Coffee Maker	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:17		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	13:10	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-005
Sample Location:	Kitchen 01	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:19		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	13:15	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-006
Sample Location:	Kitchen 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:20		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	13:21	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-007
Sample Location:	Kitchen 03	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:21		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	13:26	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-008
Sample Location:	Kitchen Steamer	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:26		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.59	µg/L	15	1/10/2022	13:32	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-009
Sample Location:	Kitchen Dishwasher Room	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:29		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.60	µg/L	15	1/10/2022	13:37	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-010
Sample Location:	Kitchen Ice Machine	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:31		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	14:00	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-011
Sample Location:	Cafe Snack Bar Coffee Maker 01	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:36		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/13/2022	12:22	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-012
Sample Location:	Cafe Snack Bar	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:38		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	14:05	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-013
Sample Location:	Cafe Snack Bar Coffee Maker 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:36		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	14:11	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-014
Sample Location:	Cafeteria 01	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:40		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.20	µg/L	15	1/10/2022	14:16	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-015
Sample Location:	Cafeteria 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:43		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	46.8 **	µg/L	15	1/13/2022	12:33	JGW	8	4

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-016
Sample Location:	Room 113	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:46		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	14:22	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-017
Sample Location:	Room 109 01	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:47		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	14:27	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-018
Sample Location:	Room 109 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:48		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	14:32	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-019
Sample Location:	Main Office Teachers Lounge	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:52		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	14:38	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-020
Sample Location:	Locker Room Girls	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:56		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	36.2 **	µg/L	15	1/13/2022	12:52	JGW	4	2

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-021
Sample Location:	Gym Girls Side	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 7:58		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	14:44	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-022
Sample Location:	Cheer Rm Gym Girls Side Ice Machine	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:01		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	14:49	JGW	2	1

**Sample Matrix:** Drinking Water **Lab Sample Number:** 211227008-023  
**Sample Location:** Cheer Rm Gym Girls Side Sink **Customer Sample Number:**  
**Sampled By:** R. Sypniewski  
**Sample Date/Time:** 12/29/2021 8:02

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.20	µg/L	15	1/10/2022	15:39	JGW	2	1

**Sample Matrix:** Drinking Water **Lab Sample Number:** 211227008-024  
**Sample Location:** Gym Boys Side **Customer Sample Number:**  
**Sampled By:** R. Sypniewski  
**Sample Date/Time:** 12/29/2021 8:06

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	15:44	JGW	2	1

**Sample Matrix:** Drinking Water **Lab Sample Number:** 211227008-025  
**Sample Location:** Locker Room Boys **Customer Sample Number:**  
**Sampled By:** R. Sypniewski  
**Sample Date/Time:** 12/29/2021 8:08

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	15:50	JGW	2	1

**Sample Matrix:** Drinking Water **Lab Sample Number:** 211227008-026  
**Sample Location:** Hallway By Gym 01 **Customer Sample Number:**  
**Sampled By:** R. Sypniewski  
**Sample Date/Time:** 12/29/2021 8:10

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	15:55	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-027
Sample Location:	Hallway By Gym 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:11		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	16:01	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-028
Sample Location:	Hallway by Auditorium 01	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:23		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	11.1	µg/L	15	1/10/2022	16:06	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-029
Sample Location:	Hallway by Auditorium 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:24		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	7.71	µg/L	15	1/10/2022	16:12	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-030
Sample Location:	Nurse Office PBCU10	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:27		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.55	µg/L	15	1/10/2022	16:17	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-031
Sample Location:	Room 126 Chorus	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:30		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.19	µg/L	15	1/10/2022	16:39	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-032
Sample Location:	Room 132 Band	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:33		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	29.8 **	µg/L	15	1/10/2022	0:07	JGW	4	2

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-033
Sample Location:	Room 124 Woodshop	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:35		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.93	µg/L	15	1/10/2022	16:53	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-034
Sample Location:	Hallway by Room 206	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:39		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	8.19	µg/L	15	1/10/2022	16:58	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-035
Sample Location:	Hallway by Room 223	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:40		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.63	µg/L	15	1/10/2022	17:04	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-036
Sample Location:	Room 233	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:43		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.55	µg/L	15	1/10/2022	17:09	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-037
Sample Location:	Room 329 DS	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:46		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	7.97	µg/L	15	1/10/2022	17:15	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-038
Sample Location:	Hallway By Room 321A	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:48		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.27	µg/L	15	1/10/2022	17:21	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-039
Sample Location:	Hallway By Room 303 01	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:51		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	7.66	µg/L	15	1/10/2022	17:26	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-040
Sample Location:	Hallway by Room 303 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 8:53		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.85	µg/L	15	1/10/2022	17:49	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-041
Sample Location:	Media Center Lounge	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:00		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	50.0 **	µg/L	15	1/13/2022	13:08	JGW	8	4

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-042
Sample Location:	Hallway by Room 442 01	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:07		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	18:21	JGW	2	1

**Sample Matrix:** Drinking Water **Lab Sample Number:** 211227008-043  
**Sample Location:** Hallway by Room 442 02 **Customer Sample Number:**  
**Sampled By:** R. Sypniewski  
**Sample Date/Time:** 12/29/2021 9:09

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.89	µg/L	15	1/10/2022	18:27	JGW	2	1

**Sample Matrix:** Drinking Water **Lab Sample Number:** 211227008-044  
**Sample Location:** Road Kill Cafe Ice Machine **Customer Sample Number:**  
**Sampled By:** R. Sypniewski  
**Sample Date/Time:** 12/29/2021 9:17

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	18:32	JGW	2	1

**Sample Matrix:** Drinking Water **Lab Sample Number:** 211227008-045  
**Sample Location:** Road Kill Cafe **Customer Sample Number:**  
**Sampled By:** R. Sypniewski  
**Sample Date/Time:** 12/29/2021 9:20

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	18:38	JGW	2	1

**Sample Matrix:** Drinking Water **Lab Sample Number:** 211227008-046  
**Sample Location:** Hallway by Room 410 01 **Customer Sample Number:**  
**Sampled By:** R. Sypniewski  
**Sample Date/Time:** 12/29/2021 9:23

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	18:43	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-047
Sample Location:	Hallway by Room 410 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:24		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	18:49	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-048
Sample Location:	Hallway by Locker Rm Boys 400 Wing 01	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:27		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	18:54	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-049
Sample Location:	Hallway by Locker Rm BOys 400 Wing 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:28		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	19:11	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-050
Sample Location:	Hallway Aux Gym D 01	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:31		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	19:22	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-051
Sample Location:	Hallway Aux Gym D 02	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:32		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	19:27	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-052
Sample Location:	Athletic Trainer Rm Ice Machine	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:35		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	19:33	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-053
Sample Location:	Athletic Trainer Rm Sink	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:36		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.21	µg/L	15	1/10/2022	19:39	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-054
Sample Location:	Hallway by Board Office	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:38		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.10	µg/L	15	1/10/2022	19:44	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-055
Sample Location:	Board Office Sink	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 9:39		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	12:37	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-056
Sample Location:	Outside Concession Stand	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 10:10		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	21:52	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	211227008-057
Sample Location:	Outside Track Side	Customer Sample Number:	
Sampled By:	R. Sypniewski		
Sample Date/Time:	12/29/2021 10:15		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/10/2022	22:03	JGW	2	1

NJ Lab ID# 14013 (Dover)  
 NJ Lab ID# 13033 (Marlboro)

\*\* Result does not meet NJDEP Limits.  
 NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.  
 Any method followed by an asterisk (\*) was analyzed by the Agra-Marlboro laboratory.  
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen  
 Susan VanVeen, Laboratory Manager

January 20, 2022



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

21122700  
211227008

Customer Name:	High Point Regional HS	Report to:	Michael P	Agra Environmental Services	# Asc./HCl Vials	pH: _____
Location:		same address		90 1/2 West Blackwell Street	# HCl Vials	pH: _____
Address:	299 Pidgeon Hill Rd			Dover, NJ 07801	# Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	Cl <sub>2</sub> : _____
	Wantage, NJ, 07461			Phone: (973) 989-0010	# HNO <sub>3</sub> x 2 Iron	pH: _____
Customer Contact:	Stephen McGrath			Fax: (973) 989-0156	# H <sub>2</sub> SO <sub>4</sub>	pH: _____
Phone: Work/Cell	973-875-3101 ext 1276 /	201-400-6448			# NaOH	pH: _____
					# unpreserved	_____
					# other	_____
					# other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 1 of 6

Project:	Collection	PWSID#	for laboratory use only						Field Analysis		
1st Draw Pb		NJ1924316									
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl <sub>2</sub> or PO <sub>4</sub>
211227008-001	Field Blank	12/29/21	07:09	X		DW	1	HNO3	Lead-1st Draw		
211227008-002	Hallway by Room 113 01	12/29/21	07:10	X		DW	1	HNO3	Lead-1st Draw		
211227008-003	Hallway by Room 113 02	12/29/21	07:11	X		DW	1	HNO3	Lead-1st Draw		
211227008-004	Teachers Rm Coffee Maker	12/29/21	07:17	X		DW	1	HNO3	Lead-1st Draw		
211227008-005	Kitchen 01	12/29/21	07:19	X		DW	1	HNO3	Lead-1st Draw		
211227008-006	Kitchen 02	12/29/21	07:20	X		DW	1	HNO3	Lead-1st Draw		
211227008-007	Kitchen 03	12/29/21	07:21	X		DW	1	HNO3	Lead-1st Draw		
211227008-008	Kitchen Steamer	12/29/21	07:26	X		DW	1	HNO3	Lead-1st Draw		
211227008-009	Kitchen Dishwasher Room	12/29/21	07:29	X		DW	1	HNO3	Lead-1st Draw		
211227008-010	Kitchen Ice Machine	12/29/21	07:31	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company):	Are these samples for compliance? (circle one):	Indicate laboratory location where analysis request was performed
RS/AGRA	Yes or <b>No</b>	
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Cooler Temperature Upon Receipt at lab:	
Standard <input type="checkbox"/> NJ Reduced <input type="checkbox"/> Other (Specify) _____	N/A	

Sample Custody Exchanges (Please use full legal signature)						Comments:
Relinquished By:	Date: 12/29/21	Time: 11:18	Received By:	Date: 12/29/21	Time: 11:20	NOTE: 009 Dish Rm - constant drip (cold) Preserved w/ HNO <sub>3</sub> @ 1cb 12/29/21
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous (circle one) Yes or No



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

21122700  
211227008

Customer Name:	High Point Regional HS	Report to:	Michael P	Agra Environmental Services	# Asc./HCl Vials	pH: _____
Location:		same address		90 1/2 West Blackwell Street	# HCl Vials	pH: _____
Address:	299 Pidgeon Hill Rd			Dover, NJ 07801	# Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	Cl <sub>2</sub> : _____
	Wantage, NJ, 07461			Phone: (973) 989-0010	# <u>10</u> HNO <sub>3</sub>	pH: _____
Customer Contact:	Stephen McGrath			Fax: (973) 989-0156	# H <sub>2</sub> SO <sub>4</sub>	pH: _____
Phone: Work/Cell	973-875-3101 ext 1276 /	201-400-6448			# NaOH	pH: _____
					# unpreserved	_____
					# other	_____
					# other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 2 of 6

Project:	1st Draw Pb	Collection	PWSID#	NJ1924316					for laboratory use only	Field Analysis	
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl <sub>2</sub> or PO <sub>4</sub>
211227008-011	Cafe Snack Bar Coffee Maker	12/29/21	07:36	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-012	Cafe Snack Bar	12/29/21	07:36	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-013	Cafe Snack Bar Coffee Maker	12/29/21	07:36	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-014	Cafeteria 01 <i>WF</i>	12/29/21	07:40	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-015	Cafeteria 02 <i>WF</i>	12/29/21	07:43	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-016	Room 113	12/29/21	07:46	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-017	Room 109 01	12/29/21	07:47	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-018	Room 109 02	12/29/21	07:48	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-019	Main Office Teachers Lounge	12/29/21	07:52	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-020	Locker Room Girls <i>WF</i>	12/29/21	07:56	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		

Sampled By (name/company): *RS/AGRA*

Are these samples for compliance? (circle one): Yes or **(N)**

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard  NJ Reduced  Other (Specify) \_\_\_\_\_

Cooler Temperature Upon Receipt at lab: *NA*

**Sample Custody Exchanges (Please use full legal signature)**

Relinquished By: <i>[Signature]</i>	Date: 12/29/21	Time: 11:18	Received By: <i>[Signature]</i>	Date: 12/29/21	Time: 11:20	Comments: <i>← MAIN OFFICE C19 - ORIP</i>
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	

Date Faxed \_\_\_\_\_  
Invoice Number \_\_\_\_\_

Is sample known to be hazardous? (circle one) Yes or No



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

21122700  
211227008

Customer Name:	High Point Regional HS	Report to:	Michael P	Agra Environmental Services	# Asc./HCl Vials	pH: _____
Location:			same address	90 1/2 West Blackwell Street	# HCl Vials	pH: _____
Address:	299 Pidgeon Hill Rd			Dover, NJ 07801	# Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	Cl <sub>2</sub> : _____
	Wantage, NJ, 07461			Phone: (973) 989-0010	# <u>10</u> HNO <sub>3</sub>	pH: _____
Customer Contact:	Stephen McGrath			Fax: (973) 989-0156	# H <sub>2</sub> SO <sub>4</sub>	pH: _____
Phone: Work/Cell	973-875-3101 ext 1276 /		201-400-6448		# NaOH	pH: _____
					# unpreserved	_____
					# other	_____
					# other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 3 of 6

Project: 1st Draw Pb		Collection		PWSID# NJ1924316		for laboratory use only		Field Analysis			
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl <sub>2</sub> or PO <sub>4</sub>
211227008-021	Gym Girls Side	12/29/21	07:58	X		DW	1	HNO3	Lead-1st Draw		
211227008-022	* Cheer Rm Gym Girls Side Ice M	12/29/21	08:01	X		DW	1	HNO3	Lead-1st Draw		
211227008-023	Cheer Rm Gym Girls Side Sink	12/29/21	08:02	X		DW	1	HNO3	Lead-1st Draw		
211227008-024	Gym Boys Side WF	12/29/21	08:06	X		DW	1	HNO3	Lead-1st Draw		
211227008-025	Locker Room Boys	12/29/21	08:08	X		DW	1	HNO3	Lead-1st Draw		
211227008-026	Hallway By Gym 01 WF	12/29/21	08:10	X		DW	1	HNO3	Lead-1st Draw		
211227008-027	Hallway By Gym 02 WF	12/29/21	08:11	X		DW	1	HNO3	Lead-1st Draw		
211227008-028	Hallway by Auditorium 01 WF	12/29/21	08:23	X		DW	1	HNO3	Lead-1st Draw		
211227008-029	Hallway by Auditorium 02 WF	12/29/21	08:24	X		DW	1	HNO3	Lead-1st Draw		
211227008-030	Nurse Office	12/29/21	08:27	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): RS/AGRA Are these samples for compliance? (circle one): Yes or **NO**

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard  NJ Reduced  Other (Specify)

Cooler Temperature Upon Receipt at lab: \_\_\_\_\_

**Sample Custody Exchanges (Please use full legal signature)**

Relinquished By:	Date: 12/29/21	Time: 11:18	Received By:	Date: 12/29/21	Time: 11:20	Comments: *-022 Girl Side Ice Machine
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous (circle one) Yes or No



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

21122700  
211227008

Customer Name:	High Point Regional HS	Report to:	Michael P	Agra Environmental Services	# Asc./HCl Vials	pH: _____
Location:			same address	90 1/2 West Blackwell Street	# HCl Vials	pH: _____
Address:	299 Pidgeon Hill Rd			Dover, NJ 07801	# Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	Cl <sub>2</sub> : _____
	Wantage, NJ, 07461			Phone: (973) 989-0010	# <b>IO</b> HNO <sub>3</sub>	pH: _____
Customer Contact:	Stephen McGrath			Fax: (973) 989-0156	# H <sub>2</sub> SO <sub>4</sub>	pH: _____
Phone: Work/Cell	973-875-3101 ext 1276 /	201-400-6448			# NaOH	pH: _____
					# unpreserved	_____
					# other	_____
					# other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 4 of 6

Project:	1st Draw Pb	Collection	PWSID#	NJ1924316						for laboratory use only	Field Analysis
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl <sub>2</sub> or PO <sub>4</sub>
211227008-031	Room 126 Chorus <i>WF</i>	12/29/21	08:30	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-032	Room 132 Band <i>WF</i>	12/29/21	08:33	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-033	Room 124 Woodshop <i>WF</i>	12/29/21	08:35	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-034	Hallway by Room 206 <i>WF</i>	12/29/21	08:39	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-035	Hallway by Room 223 <i>WF</i>	12/29/21	08:40	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-036	Room 233	12/29/21	08:43	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-037	Room 329	12/29/21	08:46	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-038	Hallway By Room 321A <i>WF</i>	12/29/21	08:48	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-039	Hallway By Room 303 01 <i>WF</i>	12/29/21	08:51	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-040	Hallway by Room 303 02 <i>WF</i>	12/29/21	08:53	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		

Sampled By (name/company): *RS / AGRA*

Are these samples for compliance? (circle one): Yes or **(N)**

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard  NJ Reduced  Other (Specify)

Cooler Temperature Upon Receipt at lab: \_\_\_\_\_

**Sample Custody Exchanges (Please use full legal signature)**

Relinquished By: <i>[Signature]</i>	Date: 12/29/21	Time: 11:18	Received By: <i>[Signature]</i>	Date: 12/29/21	Time: 11:20	Comments:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	

Date Faxed \_\_\_\_\_  
Invoice Number \_\_\_\_\_

Is sample known to be hazardous (circle one)  
Yes or No **(N)**



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

21122700  
211227008

Customer Name:	High Point Regional HS	Report to:	Michael P	Agra Environmental Services	# Asc./HCl Vials	pH: _____
Location:		same address		90 1/2 West Blackwell Street	# HCl Vials	pH: _____
Address:	299 Pidgeon Hill Rd			Dover, NJ 07801	# Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	Cl <sub>2</sub> : _____
	Wantage, NJ, 07461			Phone: (973) 989-0010	# HNO <sub>3</sub>	pH: _____
Customer Contact:	Stephen McGrath			Fax: (973) 989-0156	# H <sub>2</sub> SO <sub>4</sub>	pH: _____
Phone: Work/Cell	973-875-3101 ext 1276 /	201-400-6448			# NaOH	pH: _____
					# unpreserved	_____
					# other	_____
					# other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 5 of 6

Project:	1st Draw Pb	Collection	PWSID#	NJ1924316					for laboratory use only	Field Analysis	
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl <sub>2</sub> or PO <sub>4</sub>
211227008-041	Media Center Lounge	12/29/21	09:00	X		DW	1	HNO3	Lead-1st Draw		
211227008-042	Hallway by Room 442 01 <i>WF</i>	12/29/21	09:07	X		DW	1	HNO3	Lead-1st Draw		
211227008-043	Hallway by Room 442 02 <i>WP</i>	12/29/21	09:09	X		DW	1	HNO3	Lead-1st Draw		
211227008-044	Road Kill Cafe Ice Machine <i>*</i>	12/29/21	09:17	X		DW	1	HNO3	Lead-1st Draw		
211227008-045	Road Kill Cafe	12/29/21	09:20	X		DW	1	HNO3	Lead-1st Draw		
211227008-046	Hallway by Room 410 01	12/29/21	09:23	X		DW	1	HNO3	Lead-1st Draw		
211227008-047	Hallway by Room 410 02	12/29/21	09:24	X		DW	1	HNO3	Lead-1st Draw		
211227008-048	<i>+</i> Hallway by Locker Rm Boys 40C <sup>01</sup>	12/29/21	09:27	X		DW	1	HNO3	Lead-1st Draw		
211227008-049	<i>+</i> Hallway by Locker Rm Boys 40C <sup>02</sup>	12/29/21	09:28	X		DW	1	HNO3	Lead-1st Draw		
211227008-050	Hallway Aux Gym D 01	12/29/21	09:31	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): *RS/AGRA* Are these samples for compliance? (circle one): Yes or **No** Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013  
NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard  NJ Reduced  Other (Specify) \_\_\_\_\_ Cooler Temperature Upon Receipt at lab: *N/A*

**Sample Custody Exchanges (Please use full legal signature)**

Relinquished By: <i>[Signature]</i>	Date: 12/29/21	Time: 11:18	Received By: <i>[Signature]</i>	Date: 12/29/21	Time: 11:20	Comments: <i>*48: Wing 01</i> <i>*49: Wing 02</i> <i>041- Rust color</i> <i>044- No ice - used 250</i>
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	

Date Faxed \_\_\_\_\_ Invoice Number \_\_\_\_\_

Is sample known to be hazardous (circle one) Yes or No



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

21122708  
211227008

Customer Name:	High Point Regional HS	Report to:	Michael P	Agra Environmental Services	# Asc./HCl Vials	pH: _____
Location:			same address	90 1/2 West Blackwell Street	# HCl Vials	pH: _____
Address:	299 Pidgeon Hill Rd			Dover, NJ 07801	# Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	Cl <sub>2</sub> : _____
	Wantage, NJ, 07461			Phone: (973) 989-0010	# HNO <sub>3</sub>	pH: _____
Customer Contact:	Stephen McGrath			Fax: (973) 989-0156	# H <sub>2</sub> SO <sub>4</sub>	pH: _____
Phone: Work/Cell	973-875-3101 ext 1276 /	201-400-6448			# NaOH	pH: _____
					# unpreserved	_____
					# other	_____
					# other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 6 of 6

Project: 1st Draw Pb Collection **PWSID#** NJ1924316 [redacted] for laboratory use only Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl <sub>2</sub> or PO <sub>4</sub>
211227008-051	Hallway Aux Gym D 02	12/29/21	09:32	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-052	Athletic Trainer Rm Ice Machin	12/29/21	09:35	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-053	Athletic Trainer Rm Sink	12/29/21	09:36	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-054	Hallway by Board Office	12/29/21	09:38	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-055	Board Office Sink	12/29/21	09:39	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-056	Outside Concession Stand	12/29/21	10:10	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		
211227008-057	Outside Track Side	12/29/21	10:15	X		DW	1	HNO <sub>3</sub>	Lead-1st Draw		

Sampled By (name/company): RS / Agra Are these samples for compliance? (circle one): Yes or **No** Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013  
NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):  Standard  NJ Reduced  Other (Specify) Cooler Temperature Upon Receipt at lab: N/A

**Sample Custody Exchanges (Please use full legal signature)** Comments:

Relinquished By:	Date: 12/29/21	Time: 11:10	Received By:	Date: 12/29/21	Time: 11:20	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	

Date Faxed \_\_\_\_\_  
Invoice Number \_\_\_\_\_  
Is sample known to be hazardous (circle one)  
Yes or No